Table 12.1 – Renewable Energy Impacts Calculation

Conversion Formula: Step 1 Capacity (A) x Capacity Factor (B) x Annual Hours (C) = Annual Electricity Generation (D)

Step 2 Annual Electricity Generation (D) x Competing Heat Rate (E) = Annual Output (F)

Step 3 Annual Output (F) x Emissions Coefficient (G) = Annual Emissions Displaced (H)

| Technology | <u>Wind</u> | <u>Geothermal</u> | <u>Biomass</u> | Hydropower | <u>PV</u> | Solar Thermal |
|---|----------------|-------------------|----------------|-------------------|-------------|---------------|
| (A) Capacity (kW) | 8,181,033 | 2,189,957 | 6,417,795 | 79,103,834 | 168,977 | 440,800 |
| (B) Capacity Factor (%) | 36.0% | 90.0% | 80.0% | 44.2% | 22.5% | 24.4% |
| (C) Annual Hours | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 |
| (D) Annual Electricity Generation (kWh) | 25,799,706,093 | 17,265,620,227 | 44,975,908,630 | 306,239,675,812 | 333,053,696 | 705,355,200 |
| (E) Competing Heat Rate (Btu/kWh) | 10,107 | 10,107 | 10,107 | 10,107 | 10,107 | 10,107 |
| (F) Annual Output (Trillion Btu) | 261 | 175 | 455 | 3,095 | 3 | 7 |
| (G) Carbon Coefficient (MMTCB/Trillion Btu) | 0.01783 | 0.01783 | 0.01783 | 0.01783 | 0.01783 | 0.01783 |
| (H) Annual Carbon Displaced (MMTC) | 4.649 | 3.111 | 8.105 | 55.187 | 0.060 | 0.128 |

Sources: Capacity: EIA, *Annual Energy Outlook 2005*, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16, 2005. Capacity factors: Hydropower calculated from EIA, *Annual Energy Outlook 2005*, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16. All others based on DOE, *Renewable Energy Technology Characterizations*, EPRI TR-109496, 1997, and program data.

Heat Rate: EIA, Annual Energy Review 2003, DOE/EIA-0384(2003) (Washington, D.C., September 2004), Table A6.

Carbon Coefficient: DOE, GPRA2003 Data Call, Appendix B, page B-16, 2003.

Notes:

Capacity values exclude combined-heat-and-power (CHP) data but include end-use sector (industrial and commercial) non-CHP data. Competing heat rate from Fossil-Fueled Steam-Electric Plants heat rate.

Table 12.2 – Number of Home Electricity Needs Met Calculation

Conversion Formula: Step 1 Capacity (A) x Capacity Factor (B) x Annual Hours (C) = Annual Electricity Generation (D)

Step 2 Annual Electricity Generation (D) / Average Consumption (E) = Number of Households (F)

| Technology | <u>Wind</u> | <u>Geothermal</u> | Biomass | <u>Hydropower</u> | <u>PV</u> | Solar Thermal |
|---|----------------|-------------------|----------------|-------------------|-------------|----------------------|
| (A) Capacity (kW) | 8,181,033 | 2,189,957 | 6,417,795 | 79,103,834 | 168,977 | 440,800 |
| (B) Capacity Factor (%) | 36.0% | 90.0% | 80.0% | 44.2% | 22.5% | 24.4% |
| (C) Annual Hours | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 |
| (D) Annual Electricity Generation (kWh) | 25,799,706,093 | 17,265,620,227 | 44,975,908,630 | 306,239,675,812 | 333,053,696 | 942,183,512 |
| (E) Average Annual Household | | | | | | |
| Electricity Consumption (kWh) | 11,586 | 11,586 | 11,586 | 11,586 | 11,586 | 11,586 |
| (F) Number of Households | 2,226,809 | 1,490,220 | 3,881,935 | 26,431,984 | 28,746 | 81,321 |

Sources: Capacity: EIA, Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16, 2005.

Capacity factors: Hydropower calculated from EIA, *Annual Energy Outlook 2005*, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16. All others based on DOE, *Renewable Energy Technology Characterizations*, EPRI TR-109496, 1997, and program data.

Household electricity consumption: EIA, Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February), Tables A4 and A8, 2005.

Notes:

Capacity values exclude combined-heat-and-power (CHP) data but include end-use sector (industrial and commercial) non-CHP data.

Table 12.3 – Coal Displacement Calculation

Conversion Formula: Step 1 Capacity (A) x Capacity Factor (B) x Annual Hours (C) = Annual Electricity Generation (D)

Step 2 Annual Electricity Generation (D) x Conversion Efficiency (E) = Total Output (F)

Step 3 Total Output (F) / Fuel Heat Rate (G) = Quantity Fuel (H)

| Technology | <u>Wind</u> | Geothermal | <u>Biomass</u> | Hydropower | <u>PV</u> | Solar Thermal |
|--|---------------------|---------------------|---------------------|-----------------------|-------------------|----------------------|
| (A) Capacity (kW) | 8,181,033 | 2,189,957 | 6,417,795 | 79,103,834 | 168,977 | 440,800 |
| (B) Capacity Factor | | | | | | |
| (%) | 36.0% | 90.0% | 80.0% | 44.2% | 22.5% | 24.4% |
| (C) Annual Hours | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 | 8,760 |
| (D) Annual Electricity | 05 500 500 000 | 4= 00= 000 00= | 44.0== 000.000 | 000 000 0== 040 | | |
| Generation (kWh) | 25,799,706,093 | 17,265,620,227 | 44,975,908,630 | 306,239,675,812 | 333,053,696 | 942,183,512 |
| (E) Competing Heat Rate (Btu/kWh) (F) Total Output | 10,107 | 10,107 | 10,107 | 10,107 | 10,107 | 10,107 |
| (Btu) (G) Coal Heat Rate | 260,757,629,480,278 | 174,503,623,632,874 | 454,571,508,527,161 | 3,095,164,403,427,280 | 3,366,173,705,613 | 9,522,648,757,289 |
| (Btu per short ton) | 20,381,000 | 20,381,000 | 20,381,000 | 20,381,000 | 20,381,000 | 20,381,000 |
| (H) Coal (short tons) | 12,794,153 | 8,562,074 | 22,303,690 | 151,865,188 | 165,162 | 467,232 |

Sources: Capacity: EIA, Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16, 2005.

Capacity factors: Hydropower calculated from EIA, Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table A16. All others based on DOE, Renewable Energy Technology Characterizations, EPRI TR-109496, 1997 and Program data.

Conversion Efficiency: EIA, Annual Energy Review 2003, DOE/EIA-0384(2003) (Washington, D.C., September 2004), Table A6.

Heat Rate: Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table H1.

Notes:

Capacity values exclude combined-heat-and-power (CHP) data but include end-use sector (industrial and commercial) non-CHP data.

Table 12.4 – National SO_2 and Heat Input Data

| | <u>1980</u> | <u>1985</u> | <u>1990</u> | <u>1995</u> | <u>2000</u> | <u>2003</u> |
|--|----------------|----------------|----------------|----------------|----------------|----------------|
| SO ₂ (lbs) | 34,523,334,000 | 32,184,330,000 | 31,466,566,000 | 23,667,789,600 | 22,404,913,800 | 21,189,064,800 |
| Heat (MMBtu) | 17,838,745,941 | 18,414,433,865 | 19,684,094,492 | 21,874,579,916 | 25,603,420,992 | 26,000,023,795 |
| SO ₂ Heat Factor (lb/MMBtu) | 1.935 | 1.748 | 1.599 | 1.082 | 0.875 | 0.815 |

Source: EPA, Clean Air Markets Web site - Data and Maps, Emissions section, http://cfpub.epa.gov/gdm/

Table 12.5 – SO₂, NOx, CO₂ Emission Factors for Coal Fired and Non-Coal Fired Title IV Affected Units

| | <u>1996</u> | <u>1997</u> | <u>1998</u> | <u>1999</u> | <u>2000</u> | <u>2001</u> | <u>2002</u> |
|-----------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| SO ₂ (lbs/mmBtu) | | | | | | | |
| Coal | 1.241 | 1.245 | 1.222 | 1.166 | 1.036 | 1.008 | 0.976 |
| Non-Coal | 0.246 | 0.256 | 0.318 | 0.267 | 0.200 | 0.220 | 0.126 |
| Total | 1.096 | 1.093 | 1.058 | 0.999 | 0.875 | 0.843 | 0.794 |
| NO _x (lbs/mmBtu) | | | | | | | |
| Coal | 0.568 | 0.559 | 0.532 | 0.487 | 0.444 | 0.425 | 0.408 |
| Non-Coal | 0.221 | 0.234 | 0.251 | 0.244 | 0.210 | 0.176 | 0.128 |
| Total | 0.518 | 0.509 | 0.481 | 0.442 | 0.399 | 0.373 | 0.348 |
| CO ₂ (lbs/mmBtu) | | | | | | | |
| Coal | 206.377 | 205.537 | 205.677 | 205.586 | 205.646 | 205.627 | 205.672 |
| Non-Coal | 132.731 | 130.804 | 131.685 | 132.001 | 133.110 | 130.159 | 126.858 |
| Total | 195.682 | 194.056 | 192.256 | 191.956 | 191.672 | 189.809 | 188.813 |

Source: EPA, Acid Rain Program Compliance Report 2001, Emission Scorecard, updated April 2003, Table 1, http://www.epa.gov/airmarkets/emissions/score01/index.html, and EPA, Clean Air Markets Web site - Data and Maps, Emissions section, http://cfpub.epa.gov/gdm/

Table 12.6a – Sulfur Dioxide, Nitrogen Oxide, and Carbon Dioxide Emission Factors, 2003 - Electricity Generators

| | Boiler Type/ | Emission Factors | | | | |
|--|----------------------------|--------------------------------|---------------------------------|--------------------------------|--|--|
| Fuel | Firing Configuration | Sulfur Dioxide ¹ | Nitrogen Oxides ² | Carbon Dioxide ³ | | |
| Electricity Generators | | | | lbs per 10 ⁶ | | |
| Coal and Other Solid Fuels | | lbs per ton | lbs per ton | Btu | | |
| Petroleum Coke ⁴ | fluidized bed ⁵ | 39.0 x S | 21 | 225.13 | | |
| | all others | 39.0 x S | 21 | 225.13 | | |
| Refuse | all types | 3.9 | 5 | 199.82 | | |
| Wood | all types | 0.08 | 1.5 | 0 | | |
| Petroleum and Other Liquid Fuels | | lbs per 10 ³ gal | lbs per 10 ³ gal | lbs per 10 ⁶ Btu | | |
| Residual Oil ⁶ | tangential | 157.0 x S | 32 | 173.72 | | |
| | vertical | 157.0 x S | 47 | 173.72 | | |
| | all others | 157.0 x S | 47 | 173.72 | | |
| Distillate Oil ⁶ | all types | 150.0 x S | 24 | 161.27 | | |
| Methanol | all types | 0.05 | 12.4 | 138.15 | | |
| Propane (liquid) | all types | 86.5 | 19 | 139.04 | | |
| Coal-Oil Mixture | all types | 185.00 x S | 50 | 173.72 | | |
| Natural Gas and Other Gaseous Fuels | | lbs per 10 ⁶ cf | lbs per 10 ⁶ cf | lbs per 10 ⁶ Btu | | |
| Natural Gas | tangential | 0.6 | 170 | 116.97 | | |
| | all others | 0.6 | 280 | 116.97 | | |
| Blast Furnace Gas | all types | 950 | 280 | 116.97 | | |

Source: EIA, Electric Power Annual 2003, DOE/EIA-0348(2003) (Washington, D.C., December 2004) Table A1 **Notes:**

¹ Uncontrolled sulfur dioxide emission factors. "x S" indicates that the constant must be multiplied by the percentage (by weight) of sulfur in the fuel. Sulfur dioxide emission estimates from facilities with flue gas desulfurization equipment are calculated by multiplying uncontrolled emission estimates by one minus the reported sulfur removal efficiencies. Sulfur dioxide emission factors also account for small quantities of sulfur trioxide and gaseous sulfates.

² Parenthetic values are for wet bottom boilers; otherwise dry bottom boilers. If bottom type is unknown, dry bottom is assumed. Emission factors are for boilers with a gross heat rate of 100 million Btu per hour or greater.

³ Uncontrolled carbon dioxide emission estimates are reduced by 1% to account for unburned carbon.

⁴ Emission factors for petroleum coke are assumed to be the same as those for anthracite. If the sulfur content of petroleum coke is unknown, a 6 percent sulfur content is assumed.

⁵ Sulfur dioxide emission estimates from fluidized bed boilers assume a sulfur removal efficiency of 90%.

⁶ Oil types are categorized by Btu content as follows: heavy (greater than or equal to 144,190 Btu per gallon), and light (less than 144,190 Btu per gallon). cf = Cubic Feet. gal = U.S. Gallons. lbs = Pounds.

Table 12.6b – Sulfur Dioxide, Nitrogen Oxide, and Carbon Dioxide Emission Factors, 2003 - Combined Heat and Power Producers

| | Boiler Type/ | Emission Factors | | | | |
|----------------------------------|------------------------|-------------------------|---------------------|--------------------------------|--|--|
| | Firing | Sulfur | Carbon | | | |
| Fuel | Configuration | Dioxide 1 | Oxides 2 | Dioxide 3 | | |
| Coal and Other Solid Fuels | | lbs per ton | lbs per ton | lbs per 10 ⁶ Btu | | |
| Peat. | all types | 30.00 x S | 12 | 0 | | |
| Agricultural Waste | all types | 0.08 | 1.2 | 0 | | |
| Black Liquor | all types | 7 | 1.5 | 0 | | |
| Chemicals | all types | 7 | 1.5 | 0 | | |
| Closed Loop Biomass | all types | 0.08 | 1.5 | 0 | | |
| Internal | all types | 0.08 | 1.5 | 0 | | |
| Liquid Acetonitrile Waste | all types | 7 | 1.5 | 150.76 | | |
| Liquid Waste | all types | 2.8 | 2.3 | 163.29 | | |
| Municipal Solid Waste | all types | 1.7 | 5.9 | 189.48 | | |
| Petroleum Coke | all types | 39.00 x S | 14 | 225.13 | | |
| Pitch | all types | 30.00 x S | 11.1 | 0 | | |
| RailRoad Ties | all types | 0.08 | 1.5 | 0 | | |
| Red Liquor. | all types | 7 | 1.5 | 0 | | |
| Sludge | all types | 2.8 | 5 | 0 | | |
| Sludge Waste Sludge Wood | all types | 2.8 2.8 | 5 5 | 0 | | |
| Spent Sulfite Liquor | all types all types | 2.6 7 | 1.5 | 0 | | |
| Straw | all types | 0.08 | 1.5 | 0 | | |
| Sulfur | all types | 7 | 0 | 0 | | |
| Tar Coal | all types | 30.00 x S | 11.1 | 0 | | |
| Tires | all types | 38.00 x S | 21.7 | 0 | | |
| Waste Byproducts | all types | 1.7 | 2.3 | 163.29 | | |
| Waste Coal | all types | 38.00 x S | 21.7 | 0 | | |
| Wood/Wood Waste | all types | 0.08 | 1.5 | 0 | | |
| | | lbs per 10 ³ | lbs per | lbs per 10 ⁶ | | |
| Petroleum and Other Liquid Fuels | | gal | 10 ³ gal | Btu | | |
| Heavy Oil ⁴ | all types | 157.00 x S | 47 | 173.72 | | |
| Light Oil ⁴ | all types | 142.00 x S | 20 | 159.41 | | |
| Diesel | all types | 142.00 x S | 20 | 161.27 | | |
| Kerosene | all types | 142.00 x S | 20 | 159.41 | | |
| Butane (liquid) | all types | 0.09 | 21 12.4 | 143.2 | | |
| Fish Oil Methanol | all types all types | 0.5 0.5 | 12.4 12.4 | 0 138.15 | | |
| Oil Waste | all types | 0.5 147.00 x S | 12.4 | 163.61 | | |
| Propane (liquid) | all types | 0.5 | 19 | 139.04 | | |
| Sludge Oil | all types | 147.00 x S | 19 | 0 | | |
| Tar Oil | all types | 162.70 x S | 67 | 0 | | |
| Waste Alcohol | all types | 0.5 | 12.4 | 138.15 | | |
| | | | | | | |

| Natural Gas and Other Gaseous Fuels | | lbs per 10 ⁶ cf | lbs per 10 ⁶ cf | lbs per 10 ⁶ Btu |
|-------------------------------------|-----------|----------------------------|-------------------------------|--------------------------------|
| Natural Gas | all types | 0.6 | 280 | 116.97 |
| Butane (Gas) | all types | 0.6 | 21 | 143.2 |
| Hydrogen | all types | 0 | 550 | 0 |
| Landfill Gas | all types | 0.6 | 550 | 115.12 |
| Methane | all types | 0.6 | 550 | 115.11 |
| Other Gas | all types | 0.6 | 550 | 141.54 |
| Propane (Gas) | all types | 0.6 | 19 | 139.04 |

Source: EIA, Electric Power Annual 2003, DOE/EIA-0348(2003) (Washington, D.C., December 2004) Table A1

Notes:

¹ Uncontrolled sulfur dioxide emission factors. "x S" indicates that the constant must be multiplied by the percentage (by weight) of sulfur in the fuel. Sulfur dioxide emission estimates from facilities with flue gas desulfurization equipment are calculated by multiplying uncontrolled emission estimates by one minus the reported sulfur removal efficiencies. Sulfur dioxide emission factors also account for small quantities of sulfur trioxide and gaseous sulfates.

² Parenthetic values are for wet bottom boilers; otherwise dry bottom boilers. If bottom type is unknown, dry bottom is assumed. Emission factors are for boilers with a gross heat rate of 100 million Btu per hour or greater.

³ Uncontrolled carbon dioxide emission estimates are reduced by 1% to account for unburned carbon.

⁴ Oil types are categorized by Btu content as follows: heavy (greater than or equal to 144,190 Btu per gallon), and light (less than 144,190 Btu per gallon). cf = Cubic Feet. gal = U.S. Gallons. lbs = Pounds.

Table 12.7 – Global Warming Potentials (GWP)

(100-year time horizon)

| Gas | GWP | | | |
|---|--------|--|--|--|
| | SAR | | | |
| Carbon dioxide (CO2) | 1 | | | |
| Methane (CH ₄) ¹ | 21 | | | |
| Nitrous oxide (N ₂ O) | 310 | | | |
| HFC-23 | 11,700 | | | |
| HFC-32 | 650 | | | |
| HFC-125 | 2,800 | | | |
| HFC-134a | 1,300 | | | |
| HFC-143a | 3,800 | | | |
| HFC-152a | 140 | | | |
| HFC-227ea | 2,900 | | | |
| HFC-236fa | 6,300 | | | |
| HFC-4310mee | 1,300 | | | |
| CF ₄ | 6,500 | | | |
| C_2F_6 | 9,200 | | | |
| C_4F_{10} | 7,000 | | | |
| C_6F_{14} | 7,400 | | | |
| SF ₆ | 23,900 | | | |
| | | | | |

Source: EPA, Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2003, EPA 430-R-05-004 (PUBLIC DRAFT FEBRUARY 2005), Table ES-1.

Notes:

The GWP of a greenhouse gas is the ratio of global warming, or radiative forcing – both direct and indirect – from one unit mass of a greenhouse gas to that of one unit mass of carbon dioxide over a period of time.

GWP from Intergovernmental Panel and Climate Change (IPCC) Second Assessment Report (SAR) and Third Assessment Report (TAR).

Although the GWPs have been updated by the IPCC, estimates of emissions presented in this report use the GWPs from the Second Assessment Report. The UNFCCC reporting guidelines for national inventories were updated in 2002, but continue to require the use of GWPs from the SAR so that current estimates of aggregated greenhouse gas emissions for 1990 through 2001 are consistent with estimates developed prior to the publication of the TAR. Therefore, to comply with international reporting standards under the UNFCCC, official emission estimates are reported by the United States using SAR GWP values.

The indirect effect due to the production of CO_2 is not included.

¹The methane GWP includes direct effects and those indirect effects due to the production of tropospheric ozone and stratospheric water vapor.

Table 12.8 – Approximate Heat Content of Selected Fuels for Electric Power Generation

Fossil Fuels 1

| Residual Oil (million Btu per barrel) | 6.287 |
|---|--------|
| Distillate Oil (million Btu per barrel) | 5.825 |
| Natural Gas (Btu per million cubic ft) | 1,020 |
| Coal (million Btu per Short Ton) | 20.381 |

Biomass Materials²

| Switchgrass Btu per pound | 7,341 |
|---------------------------------|---------|
| Bagasse, Btu per pound | 6,065 |
| Rice Hulls, Btu per pound | 6,575 |
| Poultry Litter, Btu per pound | 6,187 |
| Solid wood waste, Btu per pound | 6-8,000 |

Sources:

^{1.} EIA, Annual Energy Outlook 2005, DOE/EIA-0383 (2005) (Washington, D.C., February 2005), Table H1.

^{2.} Animal Waste Screening Study, Electrotek Concepts, Inc., Arlington, VA. June 2001.

Table 12.9 – Approximate Heat Rates for Electricity

(Btu per Kilowatthour)

| | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2001</u> | <u>2002</u> | <u>2003</u> |
|--|-------------|-------------|-------------|-------------|-------------|-------------|
| Fossil-Fueled Steam-Electric Plants ¹ | 10,388 | 10,402 | 10,201 | 10,146 | 10,119 | 10,107 |
| Nuclear Steam-Electric Plants ² | 10,908 | 10,582 | 10,429 | 10,448 | 10,439 | 10,439 |
| Geothermal Energy Plants ³ | 21,639 | 21,096 | 21,017 | 21,017 | 21,017 | 21,017 |

Source: EIA, Annual Energy Review 2003, DOE/EIA-0384 (2003) (Washington, D.C., September 2004), Table A6

Notes:

¹ Through 2000, used as the thermal conversion factor for wood and waste electricity net generation at electric utilities. For all years, used as the thermal conversion factor for hydroelectric, solar, and wind electricity net generation. Through 2000, heat rates are for fossil-fueled steam-electric plants at electric utilities. For 2001 and 2002, heat rates are for fossil-fueled steam-electric plants at electric utilities and independent power producers. For 2003, the heat rate is for all fossil-fueled plants at electric utilities and independent power producers

² Used as the thermal conversion factor for nuclear electricity net generation.

³ Used as the thermal conversion factor for geothermal electricity net generation

Table 12.10 – Heating Degree Days by Month

| | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2001</u> | <u>2002</u> | <u>2003</u> | <u>2004</u> | <u>Normal¹</u> |
|-----------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---------------------------|
| | 007 | 700 | 000 | 005 | 770 | 0.40 | 0.57 | 0.17 |
| January | 887 | 728 | 886 | 935 | 778 | 940 | 957 | 917 |
| February | 831 | 655 | 643 | 725 | 670 | 819 | 769 | 732 |
| March | 680 | 535 | 494 | 669 | 624 | 564 | 487 | 593 |
| April | 338 | 321 | 341 | 302 | 282 | 351 | 302 | 345 |
| May | 142 | 184 | 115 | 115 | 185 | 162 | NA | 159 |
| June | 49 | 29 | 29 | 29 | 23 | 39 | NA | 39 |
| July | 5 | 6 | 12 | 8 | 3 | 2 | NA | 9 |
| August | 10 | 10 | 12 | 6 | 8 | 2 | NA | 15 |
| September | 54 | 56 | 69 | 71 | 38 | 59 | NA | 77 |
| October | 316 | 246 | 244 | 267 | 299 | 252 | NA | 282 |
| November | 564 | 457 | 610 | 400 | 561 | 477 | NA | 539 |
| December | 831 | 789 | 1,005 | 696 | 813 | 773 | NA | 817 |
| Total | 4,707 | 4,016 | 4,460 | 4,223 | 4,284 | 4,440 | NA | 4,524 |

Source: EIA, Annual Energy Review 2003, DOE/EIA-0384 (2003) (Washington, D.C., September 2004), Table 1.7

Notes:

Data exclude Alaska and Hawaii. Beginning in 2002, data are weighted by the estimated 2000 population. The population-weighted state figures are aggregated into Census divisions and the national average.

¹ Based on calculations of data from 1971-2000

Table 12.11 – Cooling Degree Days by Month

| | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2001</u> | <u>2002</u> | <u>2003</u> | <u>2004</u> | Normal ¹ |
|-----------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|---------------------|
| | | | | | | | | |
| January | 9 | 15 | 10 | 3 | 8 | 2 | 5 | 9 |
| February | 4 | 14 | 10 | 12 | 6 | 6 | 5 | 8 |
| March | 13 | 21 | 25 | 11 | 17 | 20 | 26 | 18 |
| April | 23 | 29 | 28 | 37 | 53 | 38 | 41 | 30 |
| May | 95 | 86 | 131 | 114 | 92 | 106 | NA | 97 |
| June | 199 | 234 | 221 | 220 | 242 | 196 | NA | 213 |
| July | 374 | 316 | 284 | 302 | 369 | 334 | NA | 321 |
| August | 347 | 291 | 302 | 333 | 331 | 332 | NA | 290 |
| September | 192 | 172 | 156 | 138 | 202 | 155 | NA | 155 |
| October | 42 | 57 | 50 | 46 | 57 | 64 | NA | 53 |
| November | 10 | 16 | 8 | 18 | 11 | 24 | NA | 15 |
| December | 5 | 9 | 4 | 11 | 5 | 4 | NA | 8 |
| Total | 1,313 | 1,260 | 1,229 | 1,245 | 1,393 | 1,281 | NA | 1,215 |

Source: EIA, Annual Energy Review 2003, DOE/EIA-0384 (2003) (Washington, D.C., September 2004), Table 1.8

Notes:

Data exclude Alaska and Hawaii. Beginning in 2002, data are weighted by the estimated 2000 population. The population-weighted state figures are aggregated into Census divisions and the national average.

NA = Not Available

¹ Based on calculations of data from 1971-2000